

EXHIBIT 2

Maintenance Requirements

LID BPM – Rain Barrel / Cistern

- Maintenance and regular inspections are important for proper function of rain barrels and cisterns. Maintenance requirements for rain barrels are minimal and consist only of regular inspection of the unit as a whole and any of its constituent parts and accessories.
- Inspect all components (i.e., roof connection, gutter, downspout, rain barrel/cistern, mosquito screen, overflow pipe) at least twice per year, and repair or replace as needed.
- Clean insect and debris screens as needed.
- Eliminate standing water to prevent vector breeding.

EXAMPLE ONLY

REFERENCE: Los Angeles County Low Impact Development (LID) Manual 2014 is available at the following link:
<http://dpw.lacounty.gov/ldd/web/>.

The County requires execution of a maintenance agreement to be recorded by the property owner for the on-going maintenance of any privately-maintained stormwater quality control measures. The property owner is responsible for compliance with the maintenance agreement.