



---

## FACTORY-MADE AIR DUCTS AND CONNECTORS

Factory-made flexible air ducts and connectors shall not be more than 5 feet in length and shall not be used in lieu of rigid elbows or fittings. This section is not adopted by OSHPD; however, section 603.4.1.1 indicates that flexible ducts shall not be more than 10 feet in length for OSHPD 1, 1R, 2, 3, 4, and 5 occupancies.

**EXCEPTION:** Residential occupancies

  
\_\_\_\_\_  
Carlos Clayton  
Chief Mechanical Inspector